

Energy Performance Certificate

Non-Domestic Building



Peacock Inn
714 Stannington Road
Stannington
SHEFFIELD
S6 6AJ

Certificate Reference Number:
0878-3022-0319-0800-4425

This certificate shows the energy rating of this building. It indicates the energy efficiency of the building fabric and the heating, ventilation, cooling and lighting systems. The rating is compared to two benchmarks for this type of building: one appropriate for new buildings and one appropriate for existing buildings. There is more advice on how to interpret this information on the Government's website www.communities.gov.uk/epbd.

Energy Performance Asset Rating


More energy efficient



Net zero CO₂ emissions



◀ 89 This is how energy efficient the building is.



Less energy efficient

Technical information

Main heating fuel: Natural Gas
Building environment: Heating and Natural Ventilation
Total useful floor area (m²): 321
Building complexity (NOS level): 3

Benchmarks

Buildings similar to this one could have ratings as follows:

40 If newly built

66 If typical of the existing stock

Administrative information

This is an Energy Performance Certificate as defined in SI2007:991 as amended

Assessment Software: iSBEM v3.3.b using calculation engine SBEM v3.3.b

Property Reference: 889348270000

Assessor Name: Geoff Mountford

Assessor Number: BREC400099

Accreditation Scheme: BRE Global

Employer/Trading Name: Geoff Mountford Ltd

Employer/Trading Address: Ash House, Norwell, Newark, NG23 6JW

Issue Date: 13 Mar 2009

Valid Until: 12 Mar 2019 (unless superseded by a later certificate)

Related Party Disclosure:

Recommendations for improving the property are contained in Report Reference Number: 0480-0841-7390-8222-4006

If you have a complaint or wish to confirm that the certificate is genuine

Details of the assessor and the relevant accreditation scheme are on the certificate. You can get contact details of the accreditation scheme from the Government's website at www.communities.gov.uk/epbd, together with details of the procedures for confirming authenticity of a certificate and for making a complaint.



For advice on how to take action and to find out about technical and financial assistance schemes to help make buildings more energy efficient visit www.carbontrust.co.uk or call us on **0800 085 2005**